

MM NM

217/782-9720

Village of Saugat Sewage Treatment Plant
NPDES Permit No. IL0621407
Compliance Inquiry Letter -- NPDES Permit Excursion

NOV 4 1982

Mr. Paul Saugat, President
Village of Saugat Board of Trustees
2897 Nonnante Avenue
Saugat, Illinois 62206

RECEIVED
IL Environmental Protection Agency

NOV 15 1982

Division of Water Pollution Control
Field Operations Section — Reg. VI

Gentlemen:

This inquiry concerns apparent excursions from the terms and conditions of the above referenced National Pollutant Discharge Elimination System (NPDES) Permit. Those apparent excursions are as follows:

Effluent pH has exceeded 10.0 on Discharge Monitoring Reports at Outfall 001A as follows:

May 1982	11.6
June 1982	11.4
July 1982	11.2
August 1982	10.8
September 1982	11.06

Please submit in writing, within ten (10) days of receipt of this letter, the reasons for the excursions outlined above, as well as a description of the steps which have been initiated to prevent any further recurrence of the above cited excursions from your NPDES Permit. This information should be sent to both IEPA and USEPA at the following addresses:

Illinois Environmental Protection Agency
Division of Water Pollution Control and
2200 Churchill Road
Springfield, Illinois 62706
Attention: Compliance Assurance Section

USEPA -- Region V
Enforcement Division
Compliance Unit — 13th Floor
230 South Dearborn Street
Chicago, Illinois 60604

Further, take notice that noncompliance with the provisions of the NPDES Permit may be the subject of enforcement action pursuant to Section 12(f) of the Illinois Environmental Protection Act, Ch. Ill 1/2 Ill. Rev. Stat., Sec. 1012(f)(1973).

US EPA RECORDS CENTER REGION 5



412181

Page Two

If there are any questions regarding the above, please contact Bonnie Delay by telephone at 217/782-9729.

Very truly yours,



Robert E. Gross, P.E.
Manager, Compliance Assurance Section
Division of Water Pollution Control

REB:BD:jab/5681C/14-15

cc: USEPA Enforcement Division
Compliance Assurance Section
Records Unit
Region 5
Carl Marcante, Plant Manager
Bonnie Delay